

# Emission Test Certificate

Friday September 03<sup>rd</sup>, 2021

Supplier: Gerflor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123, Australia)

Sample Description: FastFit+ Vinyl Plank

Date Tested: February 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)


Test Method: ASTM D5116:2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

**Emission Data (24 hrs exposure):**

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b></p>	<p align="center"><b>FastFit+ Vinyl Plank</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.035 mg/m<sup>2</sup>/hr</p>
<p align="center">Formaldehyde Emission Rate limit: ≤0.1 mg/m<sup>2</sup>/hr</p>	<p align="center">Formaldehyde Emission Rate: &lt;0.005 mg/m<sup>2</sup>/hr</p>
<p align="center"><b><i>We hereby certify that Creation Premium Vinyl Plank meets with requirements of Green Star Design &amp; As Built – Green Star Interiors, Green Building Council of Australia.</i></b></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Srikanth C. Srivatsa  
PhD (Chemistry)  
Scientific Consultant



Dr. Tuan Duong  
PhD, B Eng. (Chemical)  
Senior Consultant

**V2109006**