

Emission Test Certificate

Friday, May 12th 2017

Supplier: Gerflor Australia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123)

Sample Description: Primetex

Date Tested: May 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia</p> <p><i>Green Star Interiors V1.1 - 12.1.2B</i></p> <p><i>Green Star Design & As Built V1.1 - 13.1.2B</i></p>	<p>Primetex</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.031 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: <0.003 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BEng(Chemical Engineer)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV170502