

Emission Test Certificate

Friday January 28th, 2022

Supplier: Kenbrock Flooring Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123, Australia)

Sample Description: Kenbrock TruFIT Flooring Plank

Date Tested: January 2022 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116:2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (24 hrs exposure):

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">Kenbrock TruFIT</p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.094 mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit: ≤0.100 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.033 mg/m²/hr</p>
<p align="center"><i>We hereby certify that Kenbrock TruFIT flooring plank meets with requirements of Green Star Design & As Built – Green Star Interiors, Green Building Council of Australia.</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
B Sc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B Eng. (Chemical)
Senior Consultant

V2201005